

Quick Start Guide

AirSentric WB55 Indoor Air Quality Monitor

1. Pre-install check



- Test Ethernet port for internet access

2. Create HEX User Account

- Register at <https://hex2.nuwavesensors.com>
- Add your monitor and gateway [here](#)

3. Connect Gateway



- Attach antenna and point upwards
- Connect to power and Ethernet port

4. Connect Monitor



- Connect to power, wait up to 5 minutes
- Middle LED turns solid blue once fully connected

5. View Data on HEX



Notes:

- 1) It is recommended to read the Operating Manual in full – download [here](#).
- 2) Monitor should be positioned within range of gateway.
- 3) Multiple monitors form a mesh network which increases coverage. The Zigbee topology tool in your HEX dashboard can be used for verifying network signal strength during commissioning.
- 4) The gateway is pre-configured for DHCP to suit most networks. For alternative configurations see Operating Manual.